

Attestation of Conformity

No. 2018-454A

Cables for use in construction works Reaction to fire class E_{ca}

Company

Hangzhou Hikvision Digital Technology Co., Ltd.
No. 555 Qianmo Road
Binjiang District
Hangzhou 310052
China

Product description

Unscreened communication cable (U/UTP) with solid conductors
4 twisted pairs, PVC jacket

Product identification

DS-1LN5E-E U/UTP CAT5E 4P 25 AWG PVC
DS-1LN5E-E/E U/UTP CAT5E 4P 25 AWG PVC

Reaction to fire standards

- EN 50575:2014 including amendment A1:2016
- EN 60332-1-2:2004 including amendments A1:2015 and A11:2016
- EN 13501-6:2014

Reaction to fire classification

Class E_{ca}

Technical report


T828346, DANAK-19/19205

EC Cabling product ID

6700

This product has undergone a one-time test performed by FORCE Technology and complies with the requirements for the stated reaction to fire class. The classification has been carried out in accordance with EN 13501-6 for use in relation to the Construction Products Regulation (CPR) under AVCP system 3.

Hørsholm, 13 June 2019



Lars Lindskov Pedersen
Test Manager



Dennis Andersen
Head of Department